



**CORPORATION OF THE TOWNSHIP OF KILLALOE-HAGARTY-RICHARDS
ROUND LAKE CENTRE BOAT LAUNCH UPGRADES
RFT-05-2026**

TO ALL TENDERERS

This Addendum shall form part of the Contract Documents and **shall be noted in Appendix "B"** as part of the tenderer's submission. Ensure that all parties and subtrades submitting bids are aware of the items included in this Addendum.

Clarifications:

1. Closing date for tender submission extended to August 26, 2026 at 8:59:59AM Local Time.
2. To accommodate the varying manufacturer stock plank widths, please note the total length of precast ramps may vary from 13'-2" to 14'-0". Remaining space between new precast ramp panels and existing retaining walls to be infilled with compacted limestone screenings.
3. Precast marker bases insert hole size to accommodate a 1-5/8" diameter marker rod (Marker rods to be supplied by the municipality).
4. Substitute RFT Appendix "G" with Revised Appendix "G" Attached (Includes provisional cost line for Cofferdam use should it be required).
5. **INFO:** 'In-water works' permit has been applied for through MNR, if approved, this will negate the requirement for a cofferdam during construction. Please still include the provisional price for temporary cofferdam in the appendix "G" form.

TENDERER'S NAME (Company)

Date of Issue – August 18, 2026

SIGNATURE

Closing Date – August 26, 2026

NAME (please print)

Closing Time – 8:59:59 AM Local time

DATE

ADDENDA ISSUED BY

Jp2g Consultants Inc.
12 International Drive
Pembroke, Ontario K8A 6W5
Telephone: (613) 735-2507 Fax: (613) 735-4513